

SHAFT SMOKE DETECTORS SHALL SHUT DOWN FAN OPERATION FOR ALL AIR HANDLING UNITS IS ASSOCIATED MECHANICAL ROOMS AND SHALL CLOSE ALL SMOKE FIRE DAMPERS IN THE ASSOCIATED SHAFT UPON ALARM (DETECTION OF SMOKE).

ALL HVAC EQUIPMENT SHALL SHUT DOWN UPON ACTIVATION OF THE BUILDING FIRE ALARM SYSTEM.

1 SECOND LEVEL MECHANICAL PLAN
67,780 SF
1/16"=1'-0"

RECORD "AS-BUILT" DRAWINGS

These record drawings have been prepared in part of the "best" information compiled and furnished by others. The architect or engineer will not be responsible for any errors or omissions which have been incorporated into this document as a result.

DATE: MAY 16, 2006


American Institute of Health & Fitness
Raleigh, North Carolina

Second Level Mechanical Plan
Scale: 1/16"=1'-0" Elevation +452.50'

STRAHAN ASSOCIATES
8414 Falls of Neuse Rd. Suite 206 Raleigh NC 27615 919.847.2882

MECHANICAL ENGINEER

J. HYATT HAMMOND
ARCHITECTURE ENGINEERING INTERIORS
212 S. ELM ST. SUITE 300, GREENSBORO NC 27401
PHONE 336 370-8400 FAX 336 370-8420
www.jyhatthammond.com



M4.1

SHEET #
REVISION
MARCH 16, 2005